



**NOTIFIED BODY No. 1488
INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSZAWA
ph.: +48 (22) 57 96 167, +48 (22) 57 96 168, fax: +48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl



**CERTIFICATE OF CONSTANCY OF PERFORMANCE
1488-CPR-0280/W**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Fire damper GRYFIT CX-5

with fire resistance class according to EN 13501-3:2005+A1:2009

EI 60 (v_e h_o i↔o) S EI 90 (v_e h_o i↔o) S EI 120 (v_e h_o i↔o) S

general identification, intended use and performance of the product are described
in the Annex No. Z-1488-CPR-0280/W
which is an integral part of this certificate

placed on the market under the name or trade mark of:

**GRYFIT TECHNIK Sp. z o.o.
ul. Łąkowa 11
95-050 Konstantinów Łódzki
Poland**

and produced in the manufacturing plant:

48-747

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 15650:2010

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 02.11.2012 as a certificate No. 1488-CPD-0280/W (updated on 05.06.2013, 13.01.2014, 30.10.2020, 14.12.2021, 22.12.2021) and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 22.12.2021



NOTIFIED BODY No. 1488
INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT

ul. FILTROWA 1, 00-611 WARSZAWA
ph.: +48 (22) 57 96 167, +48 (22) 57 96 168, fax: +48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl



Annex No. Z-1488-CPR-0280/W page 1/1
which is an integral part of the certificate No. 1488-CPR-0280/W

Fire damper GRYFIT CX-5

Essential characteristics and performances of the product acc. to EN 15650:2010

Essential characteristics and performances	Clause	Levels and/or classes
Nominal activation conditions / sensitivity	4.2.1.2	
Sensing element response temperature	4.2.1.2.2	-
Sensing element load bearing capacity	4.2.1.2.3	
Response delay (response time)		
Closure time	4.2.1.3	-
Operational reliability		
Cycling	4.3.1 a)	-
Fire resistance		
Integrity	4.1.1 a)	E 60, E 90, E 120
Insulation	4.1.1 b)	EI 60, EI 90, EI 120
Smoke leakage	4.1.1 c)	EIS 60, EIS 90, EIS 120
Mechanical stability (under E)	4.1.1 a)	-
Maintenance of the cross section (under E)	4.1.1 a)	-
Durability of response delay		
Sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	-
Durability of operational reliability		
Open and closing cycle tests	4.3.3.2	-

Intended use:

Fire safety

Detailed identification, scope and conditions of use:

Classification report no. LBO-379.1-K/13 issued on 04.03.2013

Classification report no. LBO-379.2-K/13 issued on 04.03.2013

Classification report no. LBO-1522-K/21 issued on 14.10.2021

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng

Warsaw, 22.12.2021



**INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSAW, POLAND
tel.: + 48 (22) 57 96 167, + 48 (22) 57 96 168, fax: + 48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl

CERTIFICATION MARK

The company:

**GRYFIT TECHNIK Sp. z o.o.
ul. Łąkowa 11
95-050 Konstancin Łódzki
Poland**

being the manufacturer of the product:

Fire damper GRYFIT CX-5

is authorized to use
the ITB certification mark „WYRÓB BUDOWLANY”
during the period of validity of the certificate no. 1488-CPR-0280/W



1488-CPR-0280/W

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 22.12.2021